

Declaration regarding the efficiency of a shower heat recovery unit

Kiwa Nederland B.V. hereby declares that of the shower heat recovery unit,

Type : DSS/Bries Vertical Shower Heat Recovery Unit.
T-DW 3, Standard

Of : Bries Energietechnik

In : Roden, The Netherlands

of which a sample supplied and installed by DSS/Bries Energietechnik has been tested according to the method described in NEN 7120:2011, appendix B. The measurements have shown that the sample recovers the waste energy in the shower water with an efficiency of:

class	Flow (l/min)	Volume (l)	Efficiency (%)	Pressure loss (ΔP) (bar)
3	9.2	73	63.7	0.34
4,5,6	12.5	100	60.0	0.45

Apeldoorn, 7 November 2012



Ing. A.A. Slomp,
Product Manager,
Kiwa Nederland B.V.